

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 173

Dated: 27-5-2025

It is certified that an inspection team headed by Bhagwati Lal Meena, A. En.

(Name of Officers with designation) from PHED Sub. Dn. Sikrai

(Name of Department/ Office) inspected the MNP Public School.

(Name & Address of the school) on Ghata Mehandipur-Balaji, Sikrai, Dausa Ra.  
27-05-25 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of .....

Signature with Seal: Bhagwati Lal Meena  
जन. स्वा. अमि. विभाग

Name : Bhagwati Lal Meena

Designation : Assistant Engineer  
PHED Sub. Dn. Sikrai

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....

To

MNP Public School (P-70653)  
Ghata Mehandipur Balaji  
Teh. Sikrai, Dausa (Raj.)  
(Name & Address of the Institution)

Bhagwati Lal Meena  
MNP Public School (P-70653)  
Ghata Mehandipur Balaji  
Teh. Sikrai (Dausa) Raj.

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

27/05/25  
संज्ञित  
श्री बालाजी महिला विद्यापीठ शिक्षण संस्था  
घाटा मेहानपुर बालाजी  
(राज.)

**OFFICE OF THE JUNIOR CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, DAUSA**

**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No: Lab/Jr. Chem./Dausa/2025-26/ *515*  
To: *M/S M.N.P. Public School*  
*Ghata Mehandipur Balaji*  
*Mehandipur Balaji, Sikrai, Dausa*

*Not Valid for Water  
Quality Legal Cases  
The Sample was not Collected  
by this laboratory Staff*

Date *15/4/2025*

Reference: Your Letter No		NM dt 04/04/2025		Tehsil	Sikrai
Particulars	Source	TW			
	Location	M.N.P. Public School, Ghata Mehandipur Balaji, Mehandipur Balaji, Sikrai, Dausa			
Block		Sikrai			
Village/Town		Mehandipur Balaji			
Date of Collection		4/4/2025			
Date of receipt		4/4/2025			
Date of Examination		7/4/2025			
Private Chemical Sample No.		P-2			
Permission value as per I.S.:10500/2012					
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source			
1. pH	6.5-8.5	6.5-8.5	7.8		
2. Turbidity (NTU)	1	5	-		
3. Colour (Hazen Units)	5	15	-		
4. Odour	In Objectionable		U.O.		
5. Total Alkalinity (as CaCO <sub>3</sub> ) mg/l	200	600	340		
6. Total Hardness (as CaCO <sub>3</sub> ) mg/l	200	600	310		
7. Calcium Hardness			200		
8. Calcium (as Ca) mg/l	75	200	80		
9. Magnesium Hardness			110		
10. Magnesium (as Mg) mg/l	30	100	25		
11. Chloride (as Cl-) mg/l	250	1000	80		
12. Nitrate (as NO <sub>3</sub> -) mg/l	45	45	45		
13. Sulphate (as SO <sub>4</sub> -2) mg/l	200	400	-		
14. Fluoride mg/l	1.0	1.5	0.02		
15. Total Dissolve Solids mg/l	500	2000	667		

No: Lab/Jr. Chem./Dausa/2025-26/  
Copy to:-  
1. Chief Chemist, PHED Raj. Jaipur

*[Signature]*  
Junior Chemist  
P.H.E.D. Laboratory Dausa

Date

*[Signature]*  
**MNP Public School (P-70653)**  
**Ghata Mehandipur Balaji**  
**Teh. Sikrai (Dausa) Raj.**

*[Signature]*  
Junior Chemist  
P.H.E.D. Laboratory Dausa

*[Signature]*  
सचिव  
श्री बालाजी महिला विद्यापीठ शिक्षण संस्था  
घाटा मेहंदीपुर बालाजी  
(राज.)

Office of the Junior Chemist  
PUBLIC HEALTH ENGINEERING DEPTT. LABORATORY

Collectorate Circle, Khan Bhankhari Road, Dausa (Raj.)

No: Lab/Bact.Sec./2025-2026/354 Not Valid for Water  
Quality Legal Cases

Dated: 15/11/2024

Bacteriological Test Report of Water Sample

To

The Sample was not Collected  
by this laboratory Staff

District Dausa

M.N.P. Public School, Ghata  
Mehandipur Balaji,  
Mehandipur Balaji. Sikrai,  
Dausa

Tehsil: Sikrai

Reference: Your Letter No

NM

Dated 4/4/2025

S.No.	Private Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine mg/l	Source	Particulars of Samples	Coliform MPN/100 ml
1	B-2	4/4/2025	4/4/2025	-	TW	M.N.P. Public School, Ghata Mehandipur Balaji, Mehandipur Balaji. Sikrai, Dausa	0.0

No: Lab/Bact.Sec./2025-2026/

Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur

MNP Public School (P-70653)  
Ghata Mehandipur Balaji  
Teh. Sikrai (Dausa) Raj.

Junior Chemist  
PHED, Laboratory, Dausa  
Dated:

Junior Chemist  
PHED, Laboratory, Dausa

सचिव  
श्री बालाजी महिला विद्यापीठ शिक्षण संस्थान  
घाटा मेहंदीपुर बालाजी  
(राज.)